



Sisteme tratare si epurare apa
Tel/Fax: 0356442110, 0745416331
Str. Aprodul Movila, nr. 11, Timisoara
office@absolut2001.ro
www.absolut2001.ro

ANALIZE FIZICO-CHIMICE

Nr. 991 / 12.01.2017

Catre: SC CONSLOSERV PECIU NOU SRL
In att: D-lui Director

Nr. crt	Parametrii analizati	U/M	Valoare determinata	Valoare maxima admisa	STAS
1	AMONIU	mg/l	0,40	0,50	SR EN 26777/2002
2	FIER	µg/l	10	200	SR EN 26777/2002
3	MANGAN	µg/l	30	50	SR EN 26777/2002
4	NITRITI	mg/l	0,01	0,50	SR EN 26777/2002
5	CLOR LIBER	mg/l	0,00	0,50	SR EN 26777/2002

- Proba recoltata: de executant - proba momentana
- Foraj: Loc. Peciu Nou, Jud. Timis
- Analizele nu sunt acreditate RENAR

Cu deosebita consideratie,

Director Program
Robert Stoica

Director General
Ademir Stoica

Cod F.7.2-2
Ed. 1/Rev. 0